



- GENERAL NOTES:**
1. PROVIDE MIN. 6 MIL. APPROVED VAPOR BARRIER. ALL JOINTS TO BE LAPPED MIN. 6" AND SEALED.
 2. 4" 2800 PSI CONC. SLAB W/ 6#6 10/10 W.W.M. OR FIBERMESH/FIBERMESH ADDED TO THE CONCRETE. IN ACCORDANCE W/ ANNA'S RESTRICTIONS AND NER 284 FOR FIBERMESH OR NER-414 FOR FIBERMESH. OVER 6 MIL. THICKEN VAPOR BARRIER & TREATED FOR TERMITES.
 3. ■ INDICATES FILLED CELL W/3000 PSI CONC. FROM FR. TO BEAM W/ 1#5 REBAR TYPICAL ABOVE SLAB. HOOKED P.TG. DOWELS 9" EMBEDMENT W/ 25" EXT. ABOVE SLAB (8" O.C. MAX U.N.O.) (REFER TO NOTES)
 - INDICATES FILLED CELL W/3000 PSI CONC. W/1#3 REBAR TYPICAL BELOW SLAB. HOOKED P.TG. DOWELS 9" EMBEDMENT W/ EXT. TO TOP COURSE BELOW SLAB (8" O.C. MAX U.N.O.) (REFER TO NOTES)
 4. CONSULT W/ ANNA SPECIFICATIONS PRIOR TO POURING OR RECESSING DOOR SILLS.
 5. EXTERIOR SLABS SHALL SLOPE 1/12" PER FOOT AWAY FROM HOUSE.
 6. CONTROL JOINTS (IF SHOWN) ARE NOT REQUIRED BY CODE BUT ARE SUGGESTED (ESPECIALLY WHEN USING FIBER REINF. CONCL). CONTROL JOINTS TO BE SAW CUT A DEPTH (1/2) OF THE THICKNESS OF THE SLAB. FILL CUT W/ APPROVED JOINT MATERIAL OR USE ALTERNATE APPROVED METHOD.

FOUNDATION PLAN
SCALE: 1/4" = 1'-0"

NOTE: PLUMBER TO VERIFY LAYOUT 4 DIUV SIZES BEFORE CONSTRUCTION BEGINS

NOTE: PROVIDE #5 FILLED CELL AT 4'-0" O.C. IN STEM WALL WHERE STEM WALL EXCEEDS 4 COURSES HIGH